



**CITY OF WOODBURN**  
*ENGINEERING DIVISION*

**CONTRACT CLARIFICATION**

**PROJECT NAME:** North Front Street Utility Improvements

**PROJECT No:** 2008-022-29

**DATE:** October 31, 2008

**CLARIFICATION ISSUED BY:**

Ken Ackerman, PE

:

**REPORT NO.:**

**QUESTION:** Can street lighting conduit be installed in the same trench as joint utilities.

**REFERENCE SPECIFICATION SECTION:**

**REFERENCE DRAWING:** E20A13

**CLARIFICATION:** Yes, PGE street lighting conduit can be installed in the joint trench.

DISTRIBUTION:

1. Project Manager.
2. Contractor
3. File

Form: Contract Clarification Rev. Jan. 2005